

Fire Extinguisher Log Sheet for Mutual 56

[illegible]

A checkmark indicates:

1. Extinguisher can, hoses, and nozzles are not damaged, dented, or crushed.
2. The pin is securely attached to the handle by the breakaway twist-tie. Reasonable extinguisher access is available.
3. Nothing is blocking the fire extinguisher and it is easily accessible.
4. The extinguisher gauge is in the green.